

RESOLUTION NO. 22-50

A RESOLUTION AUTHORIZING THE ACCEPTANCE OF BID
FOR ELECTRICAL WORK IN WELL #4

WHEREAS, the City of Monticello has advertised for bids for electrical work in Well #4 located at N. Conley Street consistent with law;

WHEREAS, the following bids were received:

Ross Electric \$45,036.93

Forrest Electric Services \$43,011.62

WHEREAS, the Mayor has recommended to the City Council the acceptance of the bid of Forrest Electric Services for \$43,011.62 for electrical work in Well #4 related to said bid advertisement.


NOW, THEREFORE BE IT RESOLVED by the City Council of Monticello, Arkansas, that the City of Monticello is authorized and directed to accept the bid of Forrest Electric Services in the sum of \$43,011.62 for electrical work in Well #4 consistent with the bid specifications as advertised by City of Monticello.

(END OF RESOLUTION)

ADOPTED on this 28 day of June, 2022.



Mayor



City Clerk

Thursday May 26, 2022
Well # ~~4~~ Electrical with
Bid Opening 2:00 pm

Present:

George Chase - Mayor

Vickie Morris

Wayne Morris

Jonathan Daves

} City Employees

(2) Bids Received

1. Ross Electric

Labor & Material 45,036.13

(XVW)

Good for 30 days from Bid Date

By text from Mayor Page - Inmate to Zach Ross - extend bid price
15 days to (45)

2. Forrest Electric Services

Lights, Labor, 43,011.62

Switch gear,

Conduit

ROSS ELECTRIC, LLC

501 E. Mt. Zion Road

MONTECELLO AR 71655

(870)723-3294

ross_electric@yahoo.com

License #W 9709

May 20, 2022

Quote for City of Monticello Job: N. Conley Street Well

The following are included:

- Demo existing components
- Provide 3 lights with switches, 3 continuous powered outlets, & 2 pump controlled outlets
- Provide 3 50 watt led wallpack lights on photo eye
- Provide exhaust fan on/off switch
- Provide 8 circuit breaker box & 7.5 KVA transformer
- Provide junction box for wall controls & surge protector
- Provide 150 hp soft start with new wiring to motor
- Outdoor rated 400 amp disconnect & fuses mounted where the existing conduit underground meets building & dig it up & reuse wiring & mount it at that location

Labor & material \$45,036.93

Note: If in the process existing wires inside are not safe or are accidentally damaged they would need to be replaced & that is not figured in due to not planning on that needing done. Also, these prices are good for 30 days from date of this bid.

Sincerely,



Zack Ross

NOTICE

The City of Monticello is accepting bids for electrical work in Well #4 located at N. Conley Street. The bids should include the following:

- Demer of existing components
 - 3 lights with switches, 3 continuous powered outlets, and 2 pump-controlled outlets
 - 3 50 watt led wall pack lights on photo eye
 - Exhaust fan on/off switch
 - 8 circuit breaker box and 7.5 KVA transformer
 - Junction box for wall controls and surge protector
 - 150 hp soft start with new wiring to motor
 - Outdoor rated 400 amp disconnect, and fuses mounted where the existing underground conduit meets building and dig it up and reuse wiring and mount it at that location
 - All work must be completed within 3 months of bid acceptance.
- The City of Monticello reserves the right to reject any and all bids.

All bids should be sealed and submitted to City of Monticello, 205 E. Gaines, Monticello AR 71655 by noon of May 26th. Bids will be opened at 2:00 pm in City Hall.

Paid for by the City of Monticello in the amount of \$49,28.

#66391 5/4/21